



LISTING INFORMATION OF Combo Aluminum 90 Minute Fire Rated Category "J"
Weatherstripping

SPEC ID: 21212

Combo Aluminum Products
1100 N. Johnson Avenue

El Cajon, CA 92020

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Products Covered:

This Listing applies to the following Combo Aluminum Weather Strip Model Numbers:

- Jamb-Type Weatherstrip:
 - Models 1000, 1004, 3212
- Adhesive-Backed Weatherstrip:
 - Model 1430, Model 1830

Product Description:

Category "J" Jamb-Type 90 minute fire rated weatherstrip with aluminum carrier.

Category "J" Adhesive-Backed 90 minute fire rated weatherstrip.

For use with Listed and Labeled fire rated wood or steel doors.

Tested per UL 10c (2009), NFPA 252 (2008), and CAN4 S104 (1985).

<u>Attribute</u>	<u>Value</u>
CSI Code	08 70 00 Hardware
Fire Resistance	20 Min w/Hose Positive Pressure
Fire Resistance	45 Min Positive Pressure
Fire Resistance	90 Min Positive Pressure
Fire Resistance	60 Min Positive Pressure
Listed or Inspected	LISTED
Report Number	3198009MID-005f, 3198009MID-015
Criteria	CAN4 S104 (1985)
Criteria	NFPA 252 (2008)
Criteria	UL 10(c) (2009)
Intertek Services	Certification
Listing Section	CATEGORY J - GASKETING
Verification Testing	YES
Verification Test Type	FTIR